
AMENDMENT TO TENDER DOCUMENTS

2020-1608-01 Sanitary Sewer Rehabilitation – Spot Repairs

This Addendum shall form part of the Tender Documents and is to be read, interpreted and coordinated with all other parts. The following revisions, clarifications and instructions supersede the information contained in the original Tender Documents issued for the above-named project. **Respondents are to acknowledge this Addendum in their submission, as well as below.**

CHANGES TO ORIGINAL COMPETITION TERMS

Remove and replace AGREEMENT – ARTICLE 2 c) in its entirety with the following:

The Contractor agrees to actively commence work upon award of tender and agrees to complete the sanitary sewer main spot repairs, excluding the sanitary sewer main and service spot repairs located on Brigham Road, on or before July 15, 2021 and to complete all Works, including the sanitary sewer main and service spot repairs on Brigham Road, on or before October 30, 2021.

ADDITIONAL INFORMATION

See attached Record of Meeting dated May 6th, 2021.

The Respondent has received Addendum No. 01 (dated May 10th, 2021)

Acknowledged and Accepted By:

Signature of Respondent

Date

Name of Respondent

Name of Contracting Firm



Date:	May 6, 2021	File No.:	Meetings
Time:	2:00 pm	Location:	MSTeams
Client:	City of Moose Jaw	Project Name:	Spot Repair for CIPP Lining
Subject:	Pre-Tender Meeting	Project Number:	2020-4512
Attendees:	City of Moose Jaw: Bob Craig	Associated Engineering: Mike Binns Madison Kot	Contractors: NIS Contractors Ltd.
Distribution:	Those Present		

This Record of Meeting is considered to be complete and correct. Please advise the writer within one week of any errors or omissions, otherwise this Record of Meeting will be considered to be an accurate record of the discussions

Action by

Discussion:

1 SCOPE OF WORK

- Presented Scope of Work:
 - Completing sanitary sewer repairs in preparation for CIPP lining at seven (7) locations.
 - Seven (7) service connections and one main spot repair along Brigham road.
- Site available to contractor upon execution of contract
- Completion dates for work:
 - CIPP Lining Locations: July 15th, 2021
 - Non-lining locations - October 30th, 2021
- There is the potential for new locations to be amended based on CCTV inspection and data yet to be evaluated. These would be provided to the contractor for consideration as a Change in Scope.

2 QUESTIONS

1. Is information regarding spot repair lengths available?
A1: Yes, it is available in the drawings.
2. Is the Contractor allowed to shut down service connections for work?
A2: If the homeowner is provided notification of work and the intent to shut off services ahead of time so that they can reasonably prepare, shut downs of less than 8 hours will be permitted. It is desirable that shutdowns would typically be completed during the work day outside of peak use times. It is also felt that if the repair is properly prepared the actual time required to interrupt service should be minimal.

3 MEETING ADJOURNED.



**Associated
Engineering**

*GLOBAL PERSPECTIVE.
LOCAL FOCUS.*

RECORD OF MEETING

May 6, 2021

City of Moose Jaw