



CITY OF MOOSE JAW

Anjana Alex, Design and Development
Technician
PHONE (306) 690 2848
Email: aalex@moosejaw.ca

PARKS & RECREATION DEPARTMENT

228 Main Street North, Moose Jaw, SK
Canada S6H 3J8
www.moosejaw.ca

Instruction to Bidders

TENDER FOR HUMIDIFIER REPLACEMENT WORK LIBRARY/ ART MUSEUM

CITY OF MOOSE JAW, SASKATCHEWAN
FEBRUARY 1, 2019

INSTRUCTION TO BIDDERS

ADDENDUM #1

Existing Drawing 6.5 Requirements:

- 3.0 HUMIDIFIERS
- 3.1.0 GENERAL SPEC
- 3.1.1

The humidifier shall be described by Stulz Air Technology System, INC. of Frederick, Maryland.

Drawing 6.5 Requirements are now changed to:

- 3.0 HUMIDIFIERS
- 3.1.0 GENERAL SPEC
- 3.1.1

The humidifier shall be described by Stulz Air Technology System, INC. of Frederick, Maryland. However, bidders may quote using the approved alternate units:

- 1.) Nortec
- 2.) Carel

Bidders shall specify any cost adjustments that accompany using alternate units and also the actual cost if the original specified humidifier was to be used.



CITY OF MOOSE JAW

Anjana Alex, Design and Development
Technician
PHONE (306) 690 2848
Email: aalex@moosejaw.ca

PARKS & RECREATION DEPARTMENT

228 Main Street North, Moose Jaw, SK
Canada S6H 3J8
www.moosejaw.ca

Minutes from the site visits

- All water supply piping from the new water treatment system to the humidifier locations to be new.
- Humidifiers vents may be installed within air handlers depending on available space.
- All work to be coordinated with City of Moose Jaw as there are some spaces which will need to be accessed after hours, such as library.
- BMS control system was replaced approximately 1 year ago.
- Mechanical trade to act as General Contractor to coordinate all work including mechanical, electrical, ceiling removal/replacement, cutting, patching, etc., to provide a complete project.
- New duct transitions for humidifier installation to be galvanized steel with insulated access panels and insulated to match existing.